

CERTIFICATE OF CONFORMITY

Lead Adhesion Test Report

SCOPE: Covers all lead profiles.

DURATION: This certificate is valid from October 1st 2009 through to September 30th 2010.

METHOD OF TESTING: DURALEAD under the operating process outlined in I.S.O. 9000:2000 procedures, confirm that those products listed in the scope are tested to the EN1279 standards and exceed the requirements listed below. Adhesive tested in accordance with Appendix 2 of BS5713, Transition Scheme Document Issue 3.

PEEL TEST: Max 25mm adhesion loss after 30 minutes.

SHEAR TEST: Max 5mm displacement after 2 hours.

Derek Turner

Issued: 01/10/2009

Quality Assurance Manager